



INSTRUMENT CABINET SUB-PANEL LAYOUT

NOTES:

1. PROVIDE 4 FT. FLEXIBLE TUBING FOR CONNECTION TO BLOW-DOWN PIPE.
2. MAINTAIN TRANSMITTER CENTERLINE 6" OFF OF SUB-PANEL.
3. SUB-PANEL TO BE PAINTED WHITE ENAMEL.
4. REFER TO L-8701C FOR ITEM IDENTIFICATION.

REV. 2004

CITY OF COLUMBUS, OHIO
DEPARTMENT OF PUBLIC UTILITIES
DIVISION OF WATER

APPROVED

RC Westerfield
ADMINISTRATOR

1-21-05
DATE

STANDARD DETAIL
TANK INSTRUMENT PANEL
SUB-PANEL LAYOUT

